

Fort Goff Fish Passage and Diversion Improvement Project

Bid Addendum #1

- In the Construction Plans, the diameter of the PVC bypass return pipe has been set to 12" diameter for the pipe.
- In the Bid Package under Contractor Tasks, Installation of Fish Screen and Bypass Return System, the diameter of the PVC bypass return pipe has been set to 12" diameter.
- In the Bid Package under Contractor Tasks, Intake Structure and Conveyance System Installation, the language has been clarified to read: "The conveyance pipe will be mounted to bedrock or other large rock features in a manner agreed upon by the Contractor and Engineer."